

# City Works Referral Memo

---

**Date:** 20 October 2020  
**To:** Amy Hodgen  
**From:** Atha Athanasi  
**Property Address:** 640 Heidelberg Road, Alphington  
**Planning Application:** PLN17/0703.02

---

The waste management plan for Lot 2B, 626 Heidelberg Rd, Alphington authored by Salt and dated 20/7/20 is not satisfactory from a City Works Branch's perspective.

Issues to be rectified include, but may not be limited to the following:

1. Due to changes in waste service systems announced earlier this year by the State Government the site must consider how the 4 waste streams will be managed (Glass separation) especially with regards to the chute system.
2. Food waste diversion should be included for the commercial component of the development.
3. Please provide an explanation of how risks associated with waste management will be managed at the site.

A clause must be included in the plan regarding potential review into the service if operational requirements change