



GENERAL NOTES

- PITCHERS ARE NOMINALLY 300*225*150mm. (KERBSTONES NOM. 1500*300*300mm)
- THIS DRAWING IS TO BE READ IN CONJUNCTION WITH COUNCILS SPECIFICATION " CONSTRUCTION OF PITCHER KERB & CHANNEL AND PRAM CROSSINGS".
- DAMAGED AND UNSUITABLE BLUESTONE BLOCKS(PITCHERS) TO BE REPLACED
- INVERT JOINT TO BE NOM. 35mm, OTHER JOINTS TO BE NOM. 15mm. INVERT TO BE FINISHED TO GRADE.
- ALL MORTAR JOINTS TO HAVE A TOOL EDGE FINISH
- CEMENT TREATED CRUSHED ROCK BEDDING BELOW THE CHANNEL SHALL HAVE A MINIMUM COMPACTED DENSITY OF 90% OF THE MODIFIED AASHO VALUE. CEMENT TREATED CRUSHED ROCK IN FRONT OF THE CHANNEL SHALL HAVE A MINIMUM COMPACTED DENSITY OF 95% OF THE MODIFIED AASHO VALUE.
- THE NEED FOR AN A.G PIPE TO BE DETERMINED BY CONTRACT SPECIFICATIONS OR SUPERVISING ENGINEER.

Yarra Standard: YSD315 Drawing Title:

DRESSED KERB WITH SINGLE
PITCHER CHANNEL

Scale at A4 N.T.S

REV	DATE	DRAWN BY
A	29/11/07	HL
B	30/04/12	DKC
C	04/10/13	OK

