



## GENERAL NOTES

1. CROSSFALLS ON FOOTPATH SHALL NOT BE STEEPER THAN 1:40 (2.5%), AND COMPLY WITH OTHER DDA REQUIREMENTS
2. DIMENSIONS IN MILLIMETRES UNLESS OTHERWISE INDICATED
3. EXPANSION JOINTS (E.J.) TO BE 'CONNOLLY EXPANSION JOINT' OR APPROVED EQUIVALENT TO MATCH FULL DEPTH OF CONCRETE
4. EXPANSION JOINTS (E.J.) AT MAXIMUM 12m CENTRES AND AT THE START AND END OF NEWLY CONSTRUCTED FOOTPATH SECTIONS
5. ALL TOOL JOINTS TO BE SAW CUT WITHIN FIRST 48 HOURS OF POUR
6. ALL CONCRETE SHALL BE 25 MPa AT 28 DAYS
7. CONCRETE MIX DESIGN TO BE HANSEN IMAGECRETE EXPOSED MIX: KILMORE WITH NO PIGMENT, OTHER CONCRETE MIXES MAY BE CONSIDERED ON CASE-BY-CASE BASIS
8. A SAMPLE POUR WILL BE REQUIRED TO DETERMINE SUITABILITY OF MIX, AND WILL NEED THE APPROVAL OF THE MANAGER OF ENGINEERING (CoY) PRIOR TO WORKS PROCEEDING, THE SAMPLE POUR WILL BE A MINIMUM 1M X 1M, BE SET AND DRY WHEN INSPECTED.
9. WHERE EXCAVATED, DAMAGED OR RECONSTRUCTED, THE FULL CONCRETE BAY (JOINT TO JOINT) MUST BE RECONSTRUCTED AT A MINIMUM AND TO COUNCIL'S SATISFACTION
10. SEE SHEET 2 FOR CONCRETE FINISH EXAMPLES

Yarra Standard: YSD417

Drawing Title: Sheet 1 of 2

Alphington Exposed Aggregate Concrete Path Pedestrian

Not to Scale

| REV | DATE     | DRAWN BY |
|-----|----------|----------|
| A   | 01/07/21 | DC       |
| B   | 09/08/21 | DC       |
| C   | 23/12/21 | HL/DC    |
| D   |          |          |
|     |          |          |





ACCEPTABLE EXPOSURE



ACCEPTABLE EXPOSURE



UNEVEN EXPOSURE - NOT ACCEPTED



UNEVEN & UNDER EXPOSED - NOT ACCEPTED



UNDER EXPOSED - NOT ACCEPTED



OVER EXPOSED - NOT ACCEPTED



NEWLY LAID PANEL DOES NOT MATCH QUALITY & FINISH OF ADJACENT BAY - NOT ACCEPTED

**GENERAL NOTES**

1. CONCRETE TO HAVE CONSISTENT EXPOSURE, USING SINGLE AGGREGATE TYPE TO ALLEVIATE VARIATION
2. QUARRIED AND CRUSHED STONE CONSIDERED MORE CONSISTENT MATERIALS IN COMPARISON TO PEBBLE MIXES
3. EACH ADJACENT CONCRETE BAY MUST CONSISTENT AND MATCH EACH OTHER

**Yarra Standard: YSD417**

Drawing Title: Sheet 2 of 2

Alphington Exposed Aggregate Concrete Path Pedestrian Examples

Not to Scale

| REV | DATE     | DRAWN BY |
|-----|----------|----------|
| A   | 09/08/21 | DC       |
| B   | 28/10/21 | H.L/DC   |
|     |          |          |
|     |          |          |
|     |          |          |

