



**GENERAL NOTES**

1. A.G. PIPES FOR THIS WORK SHALL BE THE SIZE AND TYPE SHOWN ON THIS DRAWING AND SHALL COMPLY WITH THE CURRENT AUSTRALIAN STANDARDS AND THE MANUFACTURERS SPECIFICATIONS
2. FILLER MATERIALS FOR USE IN BACKFILLING TRENCHES, AROUND AND OVER PIPES SHALL CONSIST OF "NO FINE CONCRETE" OF SIZE 20 ONE SIZE AGGREGATE MIXED WITH 4% OF CEMENT AND 3.5% OF WATER BY MASS OF NO FINE STONE IN AN APPROVED MIXING PLANT. THE AGGREGATE SHALL COMPLY WITH THE RELEVANT REQUIREMENT OF VICROADS STD SPECIFICATION SECTION 702.
3. TRENCHES SHALL BE EXCAVATED TO THE DIMENSIONS AND GRADE REQUIRED BY THE DRAWINGS OR AS DIRECTED BY THE SUPERINTENDANT. A BEDDING LAYER OF NOT LESS THAN 50mm COMPACTED DEPTH OF FILLER MATERIAL SHALL BE PLACED IN THE BOTTOM OF THE TRENCH FOR ITS FULL LENGTH AND WIDTH. A.G. PIPE SHALL THEN BE LAID TRUE TO LINE AND GRADE AND FIRMLY EMBEDDED IN THE BEDDING MATERIAL WITH ADJACENT LENGTHS BOLTED TOGETHER OR CONNECTED WHERE NECESSARY. AFTER A.G. PIPE HAS BEEN INSPECTED AND APPROVED, THE FILLER MATERIALS SHALL BE PLACED TO THE HEIGHT SPECIFIED ON THIS DRAWING.

**Yarra Standard: YSD108**  
**Drawing Title:**  
 INSTALLATION OF SLOTTED PVC  
 AGRICUTURAL DRAINS (A.G DRAIN)

Scale at A4 N.T.S

REV	DATE	DRAWN BY
A	15/10/10	HL
B	30/04/12	DKC

