



### GENERAL NOTES

1. BLUESTONE BLOCKS (PITCHERS) ARE NOMINALLY 300x255x150mm.
2. PITCHER KERB TO BE LAID IN STRETCHER BOND PATTERN.
3. THIS DRAWING TO BE READ IN CONJUNCTION WITH COUNCIL SPECIFICATION "CONSTRUCTION OF PITCHER KERB AND CHANNEL AND PRAM CROSSINGS".
4. DAMAGED AND UNSUITABLE PITCHERS TO BE REPLACED.
5. ALL BLUESTONE JOINTS TO BE NO MORE THAN 15mm WIDE.
6. ALL MORTAR JOINTS TO HAVE A BRUSH FINISH.
7. CEMENT TREATED CRUSHED ROCK BEDDING BELOW THE CHANNEL SHALL HAVE A MINIMUM COMPACTED DENSITY OF 90% OF THE MODIFIED AASHO VALUE. CEMENT TREATED CRUSHED ROCK IN FRONT OF THE CHANNEL SHALL HAVE A MINIMUM COMPACTED DENSITY OF 95% OF THE MODIFIED AASHO VALUE.
8. THE NEED FOR AN A.G. PIPE TO BE DETERMINED BY CONTRACT SPECIFICATIONS OR SUPERVISING ENGINEER.

**Yarra Standard: YSD304**  
**Drawing Title:**

SINGLE PITCHER KERB

Scale at A4 N.T.S

REV	DATE	DRAWN BY
A	29/11/07	HL
B	30/04/12	DKC
c	04/10/13	OK

