



GENERAL NOTES

1. BLUESTONE BLOCKS (PITCHERS) ARE NOMINALLY 300x255x150mm.
2. PITCHER KERB AND CHANNEL TO BE LAID IN STRETCHER BOND PATTERN.
3. THIS DRAWING TO BE READ IN CONJUNCTION WITH COUNCIL SPECIFICATION "CONSTRUCTION OF PITCHER KERB AND CHANNEL AND PRAM CROSSINGS".
4. DAMAGED AND UNSUITABLE PITCHERS TO BE REPLACED.
5. INVERT TO BE FINISHED TO GRADE WITH WOODEN FLOAT. INVERT JOINT TO BE NOM. 35mm, OTHER JOINTS TO BE NOM. 15mm.
6. ALL BLUESTONE JOINTS TO BE NO MORE THAN 15mm WIDE.
7. ALL MORTAR JOINTS TO HAVE A BRUSH FINISH.
8. CEMENT TREATED CRUSHED ROCK BEDDING BELOW THE CHANNEL SHALL HAVE A MINIMUM COMPACTED DENSITY OF 90% OF THE MODIFIED AASHO VALUE. CEMENT TREATED CRUSHED ROCK IN FRONT OF THE CHANNEL SHALL HAVE A MINIMUM COMPACTED DENSITY OF 95% OF THE MODIFIED AASHO VALUE.
9. THE NEED FOR AN A.G. PIPE TO BE DETERMINED BY CONTRACT SPECIFICATIONS OR SUPERVISING ENGINEER.

Yarra Standard: YSD307

Drawing Title:

PITCHER KERB WITH SINGLE PITCHER CHANNEL

Scale at A4 N.T.S

REV	DATE	DRAWN BY
A	28/09/07	HL
B	30/04/12	DKC
C	04/10/13	OK

