



50mm MIN DEPTH 25MPa CONCRETE  
(60 slump minimum WITH 14mm STONE)



150mm MIN DEPTH 3% CEMENT TREATED  
CRUSHED ROCK (CLASS 2).  
OR  
150mm MIN DEPTH 2% CEMENT TREATED  
CRUSHED ROCK (CLASS 2) AS APPROVED  
BY COUNCIL ENGINEER.

**GENERAL NOTES :**

1. ORIGINAL LANE WAY PAVER STONES ARE NOMINALLY 300\*225\*240mm.  
LANE WAY PAVER STONES AFTER CUT - NOMINALLY SIZE 300\*225\*120mm.
2. ORIGINAL GUTTER PITCHERS STONES ARE NOMINALLY 300\*225\*150mm.  
GUTTER PITCHER STONES AFTER CUT - NOMINALLY SIZE 300\*225\*75mm.
3. LAY SAW CUT BLUESTONE PAVERS / PITCHERS WITH SMOOTH SIDE UP.
4. SLICED BLUESTONE MUST HAVE A MINIMUM OF 100mm THICK.
5. BLUESTONE PITCHERS TO BE LAID IN STRETCHER BOND PATTERN.
6. GAPS BETWEEN BLUESTONE PAVING MUST BE LESS THAN 15mm.
7. 'BROOM IN' FLUID SAND/CEMENT SLURRY WITH HANSON 320kg,  
120 SLUMP, 4% COLOUR ( OR EQUIVALENT PRODUCT AS APPROVED  
BY COUNCIL'S SUPERVISING OFFICER) INTO BLUESTONE GAPS.  
APPLY SLURRY FLUSH WITH BLUESTONES AND WASH/SPONGE  
TO REMOVE EXCESS SLURRY OFF BLUESTONE FACE.
8. THE USE OF SAWN BLUESTONE PAVER / PITCHER IS TO COMPLY WITH COUNCIL'S ROAD  
MATERIAL POLICY, STANDARD DRAWINGS, SUPPLIED PLANS OR AS DETERMINED  
BY COUNCIL'S SUPERVISING ENGINEER.



TYPICAL SAWN BLUESTONE PAVERS  
PAVING AT TRAFFIC MANAGEMENT  
DEVICE.



TOP VIEW - SAWN BLUESTONE PAVERS

**Yarra Standard:YSD518  
Drawing Title:**

TYPICAL DETAILS - SAWN BLUESTONE  
PAVER / PITCHER PAVING

Scale : N.T.S

REV	DATE	DRAWN BY
A	23/05/17	HL
B	12/10/17	HL

